

# Certificate

of  
Continued Compliance

No: 13229058/AA/02

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **PIR Detector with 20m/11 curtains & 60/1 curtain with NC relay**

Trademark: **Interlogix**

Type designation: **VE735**

Hardware / Software version: **PCB rev1 / VE700\_1-30\_CS61836.a43**

Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003 DH WEERT**

Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003 DH WEERT**

Country: **Netherlands**

Expiry date: **25 April 2021**

This certificate has THREE Annexes.

Zevenaar, 26 April 2017



Jan Willem Verwoert  
Project Manager





## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

According to EN 50131-1:2006, this equipment can be applied in installed systems up to and including security grade 2.

Safety aspects are not covered by this certificate.

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication: 20103518800-rev 3.0, 02 October 2014
- VdS GmbH: VE735\_VE736\_VdS\_report, 30 September 2004

### Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual
- RF\_071

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-2: 2008

January, 2008

## Technical features and characteristics

The product includes the following features and characteristics:



**The product as described in this certificate includes the following type designations:**

- Product description: PIR Detector with 20m/11 curtains & 60/1 curtain with NC relay
- Trademark: Interlogix
- Type designation: VE735
- Hardware version: PCB rev1
- Software version: VE700\_1-30\_CS61836.a43
  
- Product description: PIR Detector with 20m/11 curtains & 60/1 curtain with CO relay
- Trademark: Interlogix
- Type designation: VE736
- Hardware version: PCB rev1
- Software version: VE700\_1-30\_CS61836.a43