

Certificate

for

REQ registration

No.: 09223029/AA/01

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate is intended for registration of alarm equipment according to the requirements specified in Stichting Registratie European Quality Mark (REQ), based on verification of Quality in Production by Telefication.

Product description: **Keypad**
Trademark: **See annex 3**
Family name: **NetworX**
Type designation: **See annex 3**
Serial No: **See annex 3**
Hard- / Softw. release No: **1064339 / KWL 04.18**


Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH Weert**
Country: **Netherlands**

This additional certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH Weert**
Country: **Netherlands**

This additional certificate has THREE Annexes. Expiry Date: 05 October 2014

Zevenaar, 13 October 2011



W.J.M. Jong
Operations Manager
Certification



*Annex 1 to additional Certificate for REQ registration
Number: 09223029/AA/01*

13 October 2011
Annex 1, Page 1 of 1

Remarks and observations

The following conditions are applicable:

Wired Keyboard, Intended for use with the NetworX control panel range.
This certificate does not cover the electrical safety aspects of EN 50131-3.

Equipment Security Grade: 2
Equipment Environmental Class: II
Equipment Class: Movable or Fixed
Operational temperature: from -10 up to +55 degrees Celcius

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 2.

Follow-up of REQ Certificate issued on the 11th of February 2011.

Documentation lodged for this examination

Test Reports:

- Telefication B.V.: 20082489800 - Rev. 1, 02 February 2011
- Telefication B.V.: 20094336800 - Rev. 2, 02 February 2011

Product Documentation:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

Technical Standards and Specifications

- | | |
|-----------------|---------------|
| - EN 50130-4 | December 1995 |
| - EN 50130-4/A1 | April 1998 |
| - EN 50130-4/A2 | January 2003 |
| - EN 50131-1 | October 2006 |
| - EN 50131-1/A1 | May 2009 |
| - EN 50131-3 | March 2009 |

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

The product as described in this additional Certificate includes the following type designations:

Product description: Keypad
Type designation: NX-1048-EN
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: 1064339 / KWL 04.18

Product description: Keypad
Type designation: SC1048-EN
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: 1064339 / KWL 04.18

Product description: Keypad
Type designation: NX-1048-D-EN
Trademark: Interlogix
Serial No: --
Hard- / Softw. release No: 1064339 / KWL 04.18