

# Certificate

of Continued Compliance

## No: 13229073/AA/02

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

> Product des<mark>cription: ATS keypad</mark> Trademark: Interlogix Type designation: ATS1135 Hardware / Software version: T22Z57 / V11 Variants: See Annex 3

> > Manufacturer: UTC Fire & Security B.V. Address: Kelvinstraat 7 City: 6003 DH WEERT Country: Netherlands

> > > This certificate is granted to:

Name: UTC Fire & Security B.V. Address: Kelvinstraat 7 City: 6003 DH WEERT Country: Netherlands

Expiry date: 20 June 2021

This certificate has THREE Annexes.

Zevenaar, 12 June 2017

Jan Willem Verwoert Project Manager











#### **Remarks and observations**

The following conditions are applicable:

Equipment Security grade: 3 Equipment Environmental class: II Equipment class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 3

The equipment has been tested in combination with the control panel ATS2000A, which is considered by the manufacturer as representative for the Advisor Advanced series control panels.

This certificate does not cover the electrical safety aspects of EN 50131-1



### Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 20113828800 rev 2.0, 25 June 2014

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual
- RF\_071

#### **Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-3:2009

March, 2009

#### Technical features and characteristics

The product includes the following features and characteristics:

#### Not specified

-



## The product as described in this certificate includes the following type designations:

<ul> <li>Product description:</li> <li>Trademark:</li> <li>Type designation:</li> <li>Hardware version:</li> <li>Software version:</li> </ul>	ATS keypad Interlogix ATS1135 T22Z57 V11
<ul> <li>Product description:</li> <li>Trademark:</li> <li>Type designation:</li> <li>Hardware version:</li> <li>Software version:</li> </ul>	ATS Keypad Interlogix ATS1135S44 T22Z57 V11