

# Certificate

of  
Continued Compliance

No: 13229055/AA/01

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **DGP (Data Gathering Panel)**

Trademark: **Interlogix**

Type designation: **ATS1238**

Serial No: **N/A**

Hardware / Software version: **55-950 rev B / V024**

Variants: --

Manufacturer: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003 DH WEERT**

Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003 DH WEERT**

Country: **Netherlands**

Expiry date: **12 September 2021**

This certificate has THREE Annexes.

Zevenaar, 22 December 2017



Jan Willem Verwoert  
Project Manager



## Remarks and observations

The following conditions are applicable:

Equipment Security grade: 2

Equipment Environmental class: II

Equipment class: Fixed

The ATS1238 is meant to be installed in a UTC Fire and Security alarm control panel enclosure ATS1000A-IP-LP and ATS1000A-LP.

The ATS1238 can also be placed outside a UTC Fire and Security alarm control panel enclosure using the ATS7072 kit.

The ATS7072 kit consists of the ATS7070 (master) and ATS7071 (slave) and the housing TX-9000-03-1. The ATS1238 will be placed inside the TX-9000-03-1.

According to EN 50131-1:2006 + A1:2009, this equipment can be applied in installed systems up to and including security grade 2.

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication B.V.: 20103407800rev.2.0, 15 July 2013
- Telefication B.V.: 20124226200rev1.0, 10 July 2013
- Telefication B.V.: 20124226800rev1.0, 10 July 2013
- Telefication B.V.: 20124226801rev1.0, 10 July 2013
- Telefication: 160100453-004-Ver 2.00, 22 December 2017

### Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3:2009	March, 2009
EN 50131-5-3:2005 + A1:2008	2008

## Technical features and characteristics

The product includes the following features and characteristics:

### Alarm equipment using RF techniques

- Operating frequency range: 868.350 MHz to 868.650 MHz
-



**The product as described in this certificate includes the following type designations:**

- Product description: DGP (Data Gathering Panel)
- Trademark: Interlogix
- Type designation: ATS1238
- Hardware version: 55-950 rev B
- Software version: V024
- Serial number: N/A