

# Certificate

of  
Continued Compliance

No: 13229046/AA/05

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 system 5 registration including yearly factory inspection and market surveillance.

Product description: **Intrusion Control panel**  
Trademark: **Interlogix**  
Type designation: **ATS2604E**  
Hardware / Software version: **1056242 / 04.11.10**  
Variants: **See Annex 3**

Manufacturer: **UTC FIRE&SECURITY POLSKA SP.Z.O.O.**  
Address: **Sadowa 8**  
City: **80-771 GDANSK**  
Country: **Poland**

This certificate is granted to:

Name: **UTC FIRE&SECURITY POLSKA SP.Z.O.O.**  
Address: **Sadowa 8**  
City: **80-771 GDANSK**  
Country: **Poland**

Expiry date: **24 November 2020**

This certificate has THREE Annexes.

Zevenaar, 25 November 2016



Jan Willem Verwoert  
Project Manager



## Remarks and observations

The following conditions are applicable:

Intrusion Control Panel, 8-64 zone, Integrated Security Panel with 3A PSU

The "xx" in the generic type designation ATS2yxxE stands for different country/language codes.

y relates to the size of the housing:

y=1 means a small housing, 388 x 315 x 85 mm

y=4 means a medium housing, 475 x 370 x 160 mm

y=6 means a large housing, 475 x 460 x 160 mm

Equipment Security Grade: 2 or 3 dependent on software setting.

Equipment Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 2 or 3 dependent on software setting.

Electromagnetic emission and safety aspects are not covered by this certificate.

The onboard PSTN communicators can only be used in the Security Grade 2 setting.

ATS category: SP2

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication: 160500642-002 1.00, 23 November 2016
- Telefication: 20103678200rev6.0, 12 March 2014
- Telefication: 20103678800rev4.0, 13 November 2013
- Telefication: 20103683801rev2.0, 13 November 2013
- Telefication: 20123698801rev1.0, 22 November 2012

### Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10: 2014	June, 2014
EN 50131-3:2009	March, 2009
EN 50131-6:2008	January, 2008
EN 50136-2:2013	August, 2013

## Technical features and characteristics

The product includes the following features and characteristics:

### Not specified

-

**The product as described in this certificate includes the following type designations:**

- Product description: Intrusion Control panel  
- Trademark: Interlogix  
- Type designation: ATS2604E  
- Hardware version: 1056242  
- Software version: 04.11.10

- Product description: Intrusion Control panel  
- Trademark: Interlogix  
- Type designation: ATS21xxE  
- Hardware version: 1056242  
- Software version: 04.11.10

- Product description: Intrusion Control panel  
- Trademark: Interlogix  
- Type designation: ATS24xxE  
- Hardware version: 1056242  
- Software version: 04.11.10

- Product description: Intrusion Control panel  
- Trademark: Interlogix  
- Type designation: ATS26xxE  
- Hardware version: 1056242  
- Software version: 04.11.10