




Member of



# Certificate of Conformity with European standards for Components and Systems

---

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
<b>EN-ST-000209</b>	<b>18-03-2015</b>	<b>17-03-2019</b>

---

Subject matter of Certificate:

**Alarm transmission equipment  
IRIS 600NG, 620NG, 640NG**

---

Owner of Certificate:

**Chiron Security Communications Ltd.  
Wyvols Court, Swallowfield  
GB-RG7 IWY READING**

---

Basis for certification:

**EN 50136-2:2013  
FprEN 50131-10:2013  
EN 54-21:2006**

---

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 0**

---

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in **test report:**

**140885, 140882, 140889 dated 06-03-2015**

---

VdS Schadenverhütung GmbH  
Zertifizierungsstelle  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German Insurance  
Association (GDV) accredited by DAkkS as  
certification body for fire protection and  
security products

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises **4** pages and shall only be reproduced without any modifications and including all enclosures.



Date: 18-03-2015

Managing director

Head of certification body

To Certificate No.: EN-ST-000209

Date : 18-03-2015

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>IRIS 6xxNG SPT for mounting inside existing Intruder/Fire CIE in the variants described below equipped with the common features:</p> <ul style="list-style-type: none"> <li>- Software version V2.2.0</li> <li>- USB connector for local PC configuration</li> <li>- 6 resistance supervised inputs</li> <li>- 4 relay outputs (electronically)</li> <li>- Serial interfaces (2x RS-232, 1x RS-485)</li> </ul> <p>Single path (SP5) variant with GPRS transmission path</p> <p>Single path (SP6) variant with Ethernet transmission path</p> <p>Dual path (DP4) variant with GPRS and Ethernet transmission path</p>	<p>IRIS 600NG</p> <p>IRIS 620NG</p> <p>IRIS 640 NG</p>		

To Certificate No.: EN-ST-000209

Date : 18-03-2015

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - Manual - Manual	IRIS Touch 6NG SERIES, V1.1	12.01.2015	16
	IRIS Touch Dialler Installation Manual for EN54-21 Compliant Fire Applications, V1.2	10/2014	12
Drawings: - Circuit diagram - Assembly diagram - PCB layout - Bill of material	T6xxNG-1	03.06.2014	10
	T6xxNG-1	28.05.2014	2
	T6xxNG-1	06.08.2014	6
	T6xxNG Master	03.06.2014	9

To Certificate No.: EN-ST-000209

Date : 18-03-2015

Instructions for the application of the approval component/system (see enclosure 1):

The existing I-CIE, where the IRIS 6xxNG device is mounted, specifies the EN grade of the complete alarm system.