




Member of



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
<b>EN-ST-000206</b>	<b>17-02-2015</b>	<b>16-02-2019</b>

Subject matter of Certificate:

**Magnetic contact  
MC 275**

Owner of Certificate:

**Alarmtech Sweden AB  
Alvägen 33  
SE-19133 SOLLENTUNA, SCHWEDEN**

Basis for certification:

**EN 50131-2-6:2008**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 3**

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in **test report:**

**STE 14/1676,1677 dated 11-02-2015**

**VdS Schadenverhütung GmbH**  
Zertifizierungsstelle  
Amsterdamer Str. 174  
D-50735 Köln

a company of the Gesamtverband  
der Deutschen Versicherungs-  
wirtschaft e.V. (GDV)

VdS Laboratories are accredited  
by DAKKS according to  
DIN EN ISO/IEC 17025  
as a test laboratory.  
The accreditation is valid  
for the test methods listed  
in the accreditation document

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.



Date: 17-02-2015

Managing director

Head of certification body



To Certificate No.: EN-ST-000206

Date : 17-02-2015

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Magnetic contact flush type consisting of:</p> <ul style="list-style-type: none"><li>- Magnetic switch with isochromatic four strands cable in a moulded plastic/aluminium screw enclosure Ø 11 x 36mm</li><li>- Round rod magnet made of Neodym Ø 7 x 8 mm in a moulded plastic/aluminium screw enclosure Ø 11 x 14mm</li></ul>	MC 275		



To Certificate No.: EN-ST-000206

Date : 17-02-2015

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Instruction Manual (English)	Rev. MC275_1504en	2015	2
Instruction Manual (Swedish)	Rev. MC275_1504se	2015	2
Bill of materials	Rev. MC275_1409en	2014	1
MC 275, description of layout with wiring diagram and printed circuit board	4-MC275_1409	28.11.2013	8
Datasheet Reed switch, Meder	2118015205	15.01.2013	1
Datasheet Reed switch, Meder	2119415692	27.03.2014	1
Accessory list	Rev. MC275_1345en	2013	2
Construction drawings:			
- Screw in enclosure 36mm	4-MC200-03	18.09.2012	1
- Screw in enclosure 22mm	4-MC200-02	18.09.2012	1
- Flange 19mm	4-MC200-07	18.09.2012	1
- Flange 25mm	4-MC200-08	18.09.2012	1
- Flange 19mm	4-MC200-11	18.09.2012	1



**Enclosure 3**

**Sheet 1**

To Certificate No.: **EN-ST-000206**

Date : 17-02-2015

Instructions for the application of the approval component/system (see enclosure 1):

1. The device is suitable for use in intruder alarm systems according to EN 50131-1.
2. The device complies with environmental class IIIA of EN 50131-2-6.