

CERTIFICATE

No: 000083/04

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Telefication B.V. certify that the product

VE735AM

is in conformity with the following standard(s)

EN 50131-2-2

Alarm systems - Intrusion and hold-up systems - Part 2-2: Intrusion detectors - Passive infrared detectors

UTC Fire & Security B.V.
Kelvinstraat 7
6003 DH WEERT
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.
This certificate is valid until:
07 January 2021

Zevenaar, 07 April 2017

Signed on behalf of Telefication B.V.



Jan Willem Verwoert
Project Manager



CERTIFICATE

No: 000083/04 - Annex No 1

Takes into account the following product and variants:

- Product description: PIR detector Anti Mask
- Trademark: Interlogix
- Type designation: VE735AM
- Hardware version: 0736R3
- Software version: V1.91

- Product description: PIR detector Anti Mask
- Trademark: Interlogix
- Type designation: VE736AM
- Hardware version: 0736R3
- Software version: V1.91

The optional features of the specifications that are included in the product and test report:

Security grade: Grade 3
Environmental class: Class II
Equipment class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 3.

The outputs of the VE735AM(S70) can be changed from isolated alarm and tamper to a Fully Supervised Loop. The VE736AM does not have this feature but the alarm relay can be either normally closed or normally open.

Test Reports:

- Telefication: 20113812805 rev 1.0, 18 December 2012
- Telefication: 99636280 Rev. 3, 26 January 2010
- Telefication: 20143542801-Ver 1.00, 30 July 2014

CERTIFICATE

No: 000083/04 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual
- RF_071

DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.