

Certificate

of
Continued Compliance

No: 13229024/AA/01

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **16 zone expander module**
Trademark: **Interlogix**
Type designation: **NX-216E-EN**
Hardware / Software version: **38-0002 REV 6 / E221 V2.05**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

Expiry date: **06 November 2020**

This certificate has THREE Annexes.

Zevenaar, 07 April 2017



Jan Willem Verwoert
Project Manager





Remarks and observations

The following conditions are applicable:

Equipment Security Grade: 2

Equipment Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 2.

This certificate does not cover the electrical safety aspects of EN 50131-3.

Intended for use in the NetworX control panel range.



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 20094538800 - Rev. 4, 08 March 2011
- ANPI asbl: bis-rec-698 add 11 UTC NX216 NX216EEN NX216Z8 NX507E NX508E NX534E, 28 October 2016

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual
- RF_071

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3:2009

March, 2009

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

-



The product as described in this certificate includes the following type designations:

- Product description: 16 zone expander module
- Trademark: Interlogix
- Type designation: NX-216E-EN
- Hardware version: 38-0002 REV 6
- Software version: E221 V2.05

- Product description: 8 zone expander module
- Trademark: Interlogix
- Type designation: NX-216Z8
- Hardware version: 38-0002 REV B06
- Software version: 755-A0024-E3D3