

Certificate

of
Continued Compliance

No: 142290019/AA/01

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **PIR/MW detector form A 12m 7 curt DL**
Trademark: **Interlogix**
Type designation: **DD105**
Hardware / Software version: **Rev. 2 / -**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

Expiry date: **12 March 2023**

This certificate has THREE Annexes.

Zevenaar, 12 March 2019



Jan Willem Verwoert
Project Manager





Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 2

Model DD105 is not allowed to be used in the UK

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 20104296800, 31 December 2010
- Telefication B.V.: 20143545801-Ver 2.00, 10 March 2015

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement
- RF_071_02 DD105 EN

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-2-4

February, 2008

Technical features and characteristics

The product includes the following features and characteristics:

Alarm equipment

- Operating frequency range: 2406 MHz, 2450 MHz

-



The product as described in this certificate includes the following type designations:

- Product description: PIR/MW detector form A 12m 7 curt DL
- Trademark: Interlogix
- Type designation: DD105
- Hardware version: Rev. 2
- Software version: -

- Product description: PIR/MW detector form A 12m 7 curt DL
- Trademark: Interlogix
- Type designation: DD105C
- Hardware version: Rev. 2
- Software version: -