



# Certificate of Continued Compliance 13229058/AA/05



Issued	12-08-2022	Replaces	13229058/AA/04
Expiry date	08-11-2024	Page	1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description:	PIR Detector with 20m/11 curtaind & 60/1 curtain with NC relay
Trademark:	Aritech
Type designation:	VE735
Serial No:	N/A
Hardware / Software:	0792R1 / V1.5
Variants:	See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer:	Carrier Fire & Security B.V.
Address:	Kelvinstraat 7
City:	6003DH Weert
Country:	Netherlands

This certificate is granted to:

Name of the certificate holder:	Carrier Fire & Security B.V.
Address:	Kelvinstraat 7
City:	6003DH Weert
Country:	Netherlands

Ron Scheepers  
Managing director

*This certificate has THREE Annexes.*

# CERTIFICATE

Telefication B.V.  
Kiwa FSS Products  
Wilmersdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

**Documentation lodged for this Certificate of Continued Compliance**

Test Reports:

- Telefication: 20103518800-rev 3.0, 02 October 2014
- VdS GmbH: VE735\_VE736\_VdS\_report, 30 September 2004
- Telefication: 180700985-001-Ver. 1.00, 28 February 2019
- Telefication B.V.: 200301446-001-Ver. 1.00, 08 July 2020
- Telefication B.V.: P000118234-001-Ver. 1.00, 29 July 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-2 November, 2017

**Applied Standards**

EN 50130-5 June, 2011  
EN 50130-4+A1 October, 2014  
EN 50131-1+A1+A2+A3 June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: PIR Detector with 20m/11 curtaild & 60/1 curtain with NC relay  
- Trademark: Aritech  
- Type designation: VE735  
- Hardware version: 0792R1  
- Software version: V1.5  
- Serial number: N/A

- Product description: PIR Detector with 20m/11 curtaild & 60/1 curtain with CO relay  
- Trademark: Aritech  
- Type designation: VE736  
- Hardware version: 0792R1  
- Software version: V1.5  
- Serial number: N/A