

**Telefication B.V.**

Edisonstraat 12A  
6902 PK Zevenaar  
Phone : +31 316 583 180  
Fax : +31 316 583 189  
E-mail: certification@telefication.com  
Web: www.telefication.com

# CERTIFICATE

**No. 000176/02**

In accordance with the **CertAlarm** Rules  
and Certification System 5, as defined in ISO / IEC Guide 67,  
we Telefication B.V. certify that the product

**ATS1811**

is in conformity with the following standard(s)

**EN 50131-3: 2009 Control and indicating equipment**

**UTC Fire & Security B.V.**


Kelvinstraat 7  
6003 DH Weert  
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

**03 January 2018**

Signed on behalf of Telefication B.V.  
05 September 2014



W.J.M. Jong  
Manager Product Certification



**Telefication B.V.**

Edisonstraat 12A  
6902 PK Zevenaar  
Phone : +31 316 583 180  
Fax : +31 316 583 189  
E-mail: certification@telefication.com  
Web: www.telefication.com

# CERTIFICATE

No: 000176/02 - Annex No 1

**Takes into account the following product and variants:**

- Product description: 8 way relay board
- Trademark: Interlogix
- Type Designation: ATS1811
- Hardware version: PCB4079B
- Software version: N/A

**The optional features of the specifications that are included in the product and test report:**

Equipment Security Grade: 3

Equipment Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 3.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.

**Test Report Numbers:**

- Telefication B.V.: 20103678800rev4.0, 13 November 2013
- Telefication B.V.: 20103678200rev.6.0, 12 March 2014
- VdS GmbH: STE 04/0425, 07 June 2006

**Telefication B.V.**

Edisonstraat 12A  
6902 PK Zevenaar  
Phone : +31 316 583 180  
Fax : +31 316 583 189  
E-mail: certification@telefication.com  
Web: www.telefication.com

# CERTIFICATE

No: 000176/02 - Annex No 2

**Validity of Certificate:**

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

**Documents submitted:**

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

**DISCLAIMER**

The validity of this certificate is limited to products, which are equal to the one(s) examined.