

# Certificate

of  
Continued Compliance

No: 13229062/AA/02

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **Data bus isolator/repeater**  
Trademark: **Interlogix**  
Type designation: **ATS1740**  
Hardware / Software version: **PCA2047G / V1.0**

Manufacturer: **UTC Fire & Security B.V.**  
Address: **Kelvinstraat 7**  
City: **6003 DH WEERT**  
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**  
Address: **Kelvinstraat 7**  
City: **6003 DH WEERT**  
Country: **Netherlands**

Expiry date: **30 September 2021**

This certificate has THREE Annexes.

Zevenaar, 21 December 2018



Jan Willem Verwoert  
Project Manager



## Remarks and observations

The following conditions are applicable:

Equipment Security Grade: 3  
Equipment Environmental Class: II  
Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 3.

This certificate does not cover the electrical safety aspects of EN 50131-3.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.

### Factory location:

United Technologies Safety Systems  
No.80 Changjiang East Road  
QETDZ Qinhuangdao  
China

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication B.V.: 20103678200\_rev7.0, 15 September 2014
- Telefication B.V.: 20103678800rev4.0, 13 November 2013
- VdS GmbH: STE 04/0425, 07 June 2006

### Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3

March, 2009

## Technical features and characteristics

The product includes the following features and characteristics:

**Not specified**

-

**The product as described in this certificate includes the following type designations:**

- Product description: Data bus isolator/repeater
- Trademark: Interlogix
- Type designation: ATS1740
- Hardware version: PCA2047G
- Software version: V1.0