

Certificate

of
Continued Compliance

No: 13229067/AA/01

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **4 way relay board**
Trademark: **Interlogix**
Family name: **ATS**
Type designation: **ATS1810**
Hardware / Software version: **PCB4060A / N/A**
Variants: --

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

Expiry date: **30 September 2021**

This certificate has THREE Annexes.

Zevenaar, 13 October 2017



Arnold van der Valk
Product assessor





Remarks and observations

The following conditions are applicable:

Equipment Security Grade: 3

Equipment Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 3.

This certificate does not cover the electrical safety aspects of EN 50131-3.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 20103678200_rev7.0, 15 September 2014
- VdS GmbH: STE 04/0425, 07 June 2006
- Telefication: 20103678800rev4.0, 13 November 2013

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3

March, 2009

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

-



The product as described in this certificate includes the following type designations:

- Product description: 4 way relay board
- Trademark: Interlogix
- Family name: ATS
- Type designation: ATS1810
- Hardware version: PCB4060A
- Software version: N/A