

# CERTIFICATE

No: 000183/03

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we  
Telefication B.V. certify that the product

**ATS1810**

is in conformity with the following standard(s)

**EN 50131-3**

Alarm systems - Intrusion and hold-up systems - Part 3: Control and indicating equipment

**UTC Fire & Security B.V.**

Kelvinstraat 7  
6003 DH WEERT  
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:  
08 March 2022

Zevenaar, 21 December 2018

Signed on behalf of Telefication B.V.



Jan Willem Verwoert  
Project Manager



# CERTIFICATE

No: 000183/03 - Annex No 1

## Takes into account the following product and variants:

- Product description: 4 way relay board
- Trademark: Interlogix
- Family name: ATS
- Type designation: ATS1810
- Hardware version: PCB4060A
- Software version: N/A

## The optional features of the specifications that are included in the product and test report:

Security grade: 3  
Environmental class: II  
Equipment class: Fixed

According to EN 50131-1:2006, this equipment can be applied in installed systems up to and including security grade 3.

Electromagnetic emission and safety aspects are not covered by this certificate.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.

Factory location:  
United Technologies Safety Systems  
No.80 Changjiang East Road  
QETDZ Qinhuangdao  
China

## Not specified

-

## Test Reports:

- Telefication: 20103678200\_rev7.0, 15 September 2014
- VdS GmbH: STE 04/0425, 07 June 2006
- Telefication: 20103678800rev4.0, 13 November 2013

# CERTIFICATE

No: 000183/03 - Annex No 2

## Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

## Documents submitted:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

## DISCLAIMER:

The validity of this certificate is limited to products, which are equal to the one(s) examined.