telefication

**Telefication B.V.**
Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

# CERTIFICATE

**No: 000157/04**

In accordance with the **CertAlarm** Rules and Certification scheme type 5, as defined in ISO/IEC 17067, we Telefication B.V. certify that the product

## ATS1211E

is in conformity with the following standard(s)

**EN 50131-3**
Alarm systems - Intrusion and hold-up systems - Part 3: Control and indicating equipment

**UTC Fire & Security B.V.**
Kelvinstraat 7
6003 DH WEERT
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.
This certificate is valid until:
03 January 2022

Zevenaar, 21 December 2018
Signed on behalf of Telefication B.V.

Jan Willem Verwoert
Project Manager

PRODUCTS
RvA C 224



This certificate and the annex(es) may only be copied completely and without any additions.

**Telefication B.V.**
Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

# CERTIFICATE

## No: 000157/04 - Annex No 1

**Takes into account the following product and variants:**

| | |
|---|---|
| - Product description: | 8 -16 zone DGP expander |
| - Trademark: | Interlogix |
| - Family name: | ATS |
| - Type designation: | ATS1211E |
| - Hardware version: | 1051623 |
| - Software version: | V2.6 |

| | |
|---|---|
| - Product description: | 8 -16 zone DGP expander |
| - Trademark: | Interlogix |
| - Family name: | ATS |
| - Type designation: | ATS1210E |
| - Hardware version: | 1051623 |
| - Software version: | V2.6 |

| | |
|---|---|
| - Product description: | 8 -16 zone DGP expander |
| - Trademark: | Interlogix |
| - Family name: | ATS |
| - Type designation: | ATS1210LE |
| - Hardware version: | 1051623 |
| - Software version: | V2.6 |

**The optional features of the specifications that are included in the product and test report:**

8 Zones Expander module with variants ATS1211E and ATS1210E and ATS1210LE.
The units are identical in schematic and PCB lay-out, only the enclosure for the three units is different.
ATS1210E: Polycarbonate housing, dimensions 86 x 125 x 36 mm
ATS1210LE: Polycarbonate housing, dimensions 120 x 240 x 38 mm
ATS1211E: Metal housing with coating, dimensions 165 x 125 x 36 mm

Equipment Security Grade: 3
Equipment Environmental Class: II
Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this DGP equipment can be applied with ATS Classic EN Control panels, up to and including Security Grade 3.

This certificate does not cover the electrical safety aspects of EN 50131-3.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.

Factory location:



This certificate and the annex(es) may only be copied completely and without any additions.

telefication

Telefication B.V.
Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

# CERTIFICATE

## No: 000157/04 - Annex No 1

United Technologies Safety Systems
No.80 Changjiang East Road
QETDZ Qinhuangdao
China

**Not specified**
-

**Test Reports:**

- Telefication: 20113464800 - Rev. 2.0, 22 September 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E1, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E2, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911:A, 28 January 2011
- Telefication: 151200964-013-Ver 1.00, 05 September 2016



This certificate and the annex(es) may only be copied completely and without any additions.

# CERTIFICATE

## No: 000157/04 - Annex No 2

**Telefication B.V.**
Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

**Validity of Certificate:**

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

**Documents submitted:**

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

**DISCLAIMER:**

The validity of this certificate is limited to products, which are equal to the one(s) examined.



This certificate and the annex(es) may only be copied completely and without any additions.