

CERTIFICATE

No. 000157/02

In accordance with the **CertAlarm** Rules
and Certification System 5, as defined in ISO / IEC Guide 67,
we Telefication B.V. certify that the product

ATS1211E

is in conformity with the following standard(s)

EN 50131-3: 2009 Control and indicating equipment

UTC Fire & Security B.V.


Kelvinstraat 7
6003 DH Weert
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

03 January 2018

Signed on behalf of Telefication B.V.
09 September 2014



W.J.M. Jong
Manager Product Certification



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000157/02 - Annex No 1

Takes into account the following product and variants:

- Product description: 8 -16 zone DGP expander
- Trademark: Interlogix
- Type Designation: ATS1211E
- Hardware version: 1051623
- Software version: V2.4

- Product description: 8 -16 zone DGP expander
- Trademark: Interlogix
- Type Designation: ATS1210E
- Hardware version: 1051623
- Software version: V2.4

- Product description: 8 -16 zone DGP expander
- Trademark: Interlogix
- Type Designation: ATS1210LE
- Hardware version: 1051623
- Software version: V2.4

The optional features of the specifications that are included in the product and test report:

8 Zones Expander module with variants ATS1211E and ATS1210E and ATS1210LE.

The units are identical in schematic and PCB lay-out, only the enclosure for the three units is different.

ATS1210E: Polycarbonate housing, dimensions 86 x 125 x 36 mm

ATS1210LE: Polycarbonate housing, dimensions 120 x 240 x 38 mm

ATS1211E: Metal housing with coating, dimensions 165 x 125 x 36 mm

Equipment Security Grade: 3

Equipment Environmental Class: II

Equipment Class: Fixed

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

According to EN 50131-1:2006 and A1:2009, this DGP equipment can be applied with ATS Classic EN Control panels, up to and including Security Grade 3.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS34xxE, ATS36xxE and ATS46xxE.

Test Report Numbers:

- Telefication B.V.: 20113464800 - Rev. 2.0, 22 September 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E1, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E2, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911:A, 28 January 2011
- Telefication B.V.: 20103678200rev6.0, 12 March 2014

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000157/02 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

DISCLAIMER

The validity of this certificate is limited to products, which are equal to the one(s) examined.