

Certificate of **Continued Compliance** 13229070/AA/03



16-08-2021 Replaces 13229070/AA/02

16-08-2025 1/4 Expiry date Page

In compliance with the procedure specified in the Alarm Components Scheme, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: 8 -16 zone DGP expander

Trademark: ARITECH Type designation: ATS1211E Hardware / Software: 1051623 / V2.8 Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Carrier Fire & Security B.V.

Kelvinstraat 7 Address: 6003DH Weert City: Country: Netherlands

This certificate is granted to:

Name of the certificate holder: Carrier Fire & Security B.V.

Kelvinstraat 7 Address: City: 6003DH Weert Netherlands Country:

Ron Scheepers Telefication B.V. Managing director

This certificate has THREE Annexes.

Kiwa FSS Products Wilmersdorf 50

Postbus 137 7300 AC Apeldoorn The Netherlands

https://www.kiwa.com/nl/en /specials/fire-safety-and-security



Remarks and observations

The following conditions are applicable:

8 Zones Expander module with variants ATS1211E and ATS1210E and ATS1210LE.

The units are identical in schematic and PCB lay-out, only the enclosure for the three units is different.

ATS1210E: Polycarbonate housing, dimensions 86 x 125 x 36 mm ATS1210LE: Polycarbonate housing, dimensions 120 x 240 x 38 mm ATS1211E: Metal housing with coating, dimensions 165 x 125 x 36 mm

Security Grade: 3 Environmental Class: II Equipment Class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3. Electromagnetic emission and safety aspects are not covered by this certificate.

Intended for use in combination with Interlogix Alarm Control Panels with type designations ATS21xxE, ATS24xxE, ATS26xxE, ATS31xxE, ATS36xxE and ATS46xxE.

Factory location: Carrier Safety Systems (Hebei) Co., Ltd. No. 80 Changjiang East Road Qinhuangdao, Hebei China

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 20113464800 Rev. 2.0, 22 September 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E1, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911-E2, 21 January 2011
- SP Sveriges Tekniska Forskningsinstitut: PX06911:A, 28 January 2011
- Telefication: 151200964-013-Ver 1.00, 05 September 2016

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3 March, 2009

Applied Standards

EN 50130-5 June, 2011 EN 50130-4+A1 October, 2014 EN 50131-1+A1+A2 May, 2017

The product as described in this certificate includes the following type designations

- Product description: 8 -16 zone DGP expander

Trademark: ARITECH
Type designation: ATS1211E
Hardware version: 1051623
Software version: V2.8

- Product description: 8 -16 zone DGP expander

Trademark: ARITECH
Type designation: ATS1210E
Hardware version: 1051623
Software version: V2.8

- Product description: 8 -16 zone DGP expander

Trademark: ARITECH
Type designation: ATS1210LE
Hardware version: 1051623
Software version: V2.8