

Certificate

of
Continued Compliance

No: 13229060//AA/02

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **8 zone input expander**
Trademark: **Interlogix**
Type designation: **ATS1201E**
Serial No: **N/A**
Hardware / Software version: **1055475 / V3.0**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

Expiry date: **21 June 2024**

This certificate has **THREE** Annexes.

Zevenaar, 22 June 2020



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Generic Type-designation ATS120xE

8-32 zone DGP expander with 3 A PSU and different sizes of the enclosure:

x=1: Small enclosure, 388 x 315 x 85 mm

x=3: Medium enclosure, 475 x 370 x 160 mm

x=4: Large enclosure, 475 x 460 x 160 mm

Equipment Security Grade: 3

Equipment Environmental Class: II

Equipment Class: Fixed

Power supply type: A

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.
Electromagnetic emission and safety aspects are not covered by this certificate.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 20113517800 - Rev. 2.0, 27 September 2011
- CNPP: LE 14 00 70, 08 September 2014
- CNPP: LE 14 00 71, 08 September 2014
- Telefication B.V.: 20103407800 - Rev. 4.0, 25 June 2014
- CNPP: LM 14 00 57, 24 July 2014
- Telefication B.V.: 190601816-001-Ver 1.00, 16 June 2020
- CNPP: AH140138, 01 December 2014

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
------------	-------------

Applied Standards

EN 50130-5	June, 2011
EN 50131-6	October, 2017
EN 50130-4+A1	October, 2014
EN 50131-1+A1+A2	May, 2017



The product as described in this certificate includes the following type designations:

- Product description: 8 zone input expander
- Trademark: Interlogix
- Type designation: ATS1201E
- Hardware version: 1055475
- Software version: V3.0
- Serial number: N/A

- Product description: 8 zone input expander
- Trademark: Interlogix
- Type designation: ATS1203E
- Hardware version: 1055475
- Software version: V3.0
- Serial number: N/A

- Product description: 8 zone input expander
- Trademark: Interlogix
- Type designation: ATS1204E
- Hardware version: 1055475
- Software version: V3.0
- Serial number: N/A