

CERTIFICATE

No. 000175/02

In accordance with the **CertAlarm** Rules
and Certification System 5, as defined in ISO/IEC 17067,
we Telefication B.V. certify that the product

ATS120xE

is in conformity with the following standard(s)

EN 50131-3: 2009
Control and indicating equipment
EN 50131-6: 2008
Power supply equipment

UTC Fire & Security B.V.
Kelvinstraat 7
6003 DH Weert
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

03 January 2018

Signed on behalf of Telefication B.V.
20 October 2014

i.o.



W.J.M. Jong
Manager Product Certification



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000175/02 - Annex No 1

Takes into account the following product and variants:

- Product description: 8 zone input expander
- Trademark: Interlogix
- Family name: ATS
- Type Designation: ATS120xE
- Hardware version: 1055475
- Software version: V2.4

- Product description: 8 zone input expander
- Trademark: Interlogix
- Family name: ATS
- Type Designation: ATS1201E
- Hardware version: 1055475
- Software version: V2.4

- Product description: 8 zone input expander
- Trademark: Interlogix
- Family name: ATS
- Type Designation: ATS1203E
- Hardware version: 1055475
- Software version: V2.4

- Product description: 8 zone input expander
- Trademark: Interlogix
- Family name: ATS
- Type Designation: ATS1204E
- Hardware version: 1055475
- Software version: V2.4

The optional features of the specifications that are included in the product and test report:

Generic Type-designation ATS120xE

8-32 zone DGP expander with 3 A PSU and different sizes of the enclosure:

x=1: Small enclosure, 388 x 315 x 85 mm

x=3: Medium enclosure, 475 x 370 x 160 mm

x=4: Large enclosure, 475 x 460 x 160 mm

Security Grade: 3

Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 3.

Test Report Numbers:

- Telefication B.V.: 20103678200 - Rev. 5.0, 30 September 2011
- Telefication B.V.: 20113517800 - Rev. 2.0, 27 September 2011
- VdS GmbH: STE 04/0425, 07 June 2006

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000175/02 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

DISCLAIMER

The validity of this certificate is limited to products, which are equal to the one(s) examined.