

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No. 000174/01

In accordance with the **CertAlarm** Rules
and Certification System 5, as defined in ISO / IEC Guide 67,
we Telefication B.V. certify that the product

ATS1135

is in conformity with the following standard(s)

EN 50131-3: 2009 Control and indicating equipment

UTC Fire & Security B.V.


Kelvinstraat 7
6003 DH Weert
Netherlands

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

04 September 2018

Signed on behalf of Telefication B.V.
11 September 2014



W.J.M. Jong
Manager Product Certification



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000174/01 - Annex No 1

Takes into account the following product and variants:

- Product description: ATS keypad
- Trademark: Interlogix
- Type Designation: ATS1135
- Hardware version: T22Z57
- Software version: V10

- Product description: ATS Keypad
- Trademark: Interlogix
- Type Designation: ATS1135S44
- Hardware version: T22Z57
- Software version: V10

The optional features of the specifications that are included in the product and test report:

Equipment Security grade: 3

Equipment Environmental class: II

Equipment class: fixed

The equipment has been tested in combination with the control panel ATS2000A, which is considered by the manufacturer as representative for the Advisor Advanced series control panels.

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 3

Test Report Numbers:

- Telefication B.V.: 20113828800 rev 2.0, 25 June 2014

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000174/01 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

DISCLAIMER

The validity of this certificate is limited to products, which are equal to the one(s) examined.