

Certificate

of
Continued Compliance

No: 13229048/AA/05

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 system 5 registration including yearly factory inspection and market surveillance.

Product description: **Intrusion Control Panel**
Trademark: **Interlogix**
Type designation: **ATS4601E**
Hardware / Software version: **1055451 / 04.11.10**
Variants: **See Annex 3**

Manufacturer: **UTC FIRE&SECURITY POLSKA SP.Z.O.O.**
Address: **Sadowa 8**
City: **80-771 GDANSK**
Country: **Poland**

This certificate is granted to:

Name: **UTC FIRE&SECURITY POLSKA SP.Z.O.O.**
Address: **Sadowa 8**
City: **80-771 GDANSK**
Country: **Poland**

Expiry date: **24 November 2020**

This certificate has THREE Annexes.

Zevenaar, 25 November 2016



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Equipment Security 2 or 3 dependen on software setting.

Equipment Environmental Class: II

Equipment Class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including Security Grade 2 or 3 dependent on software setting.

Electromagnetic emission and safety aspects are not covered by this certificate.

This certificate does not cover the electrical safety aspects of EN 50131-3.

The ATS46xxE control panel should be furbished with the metal housing ATS1642.

The "xx" in type designation ATS46xxE stands for different country/language codes.

The onboard PSTN communicators can only be used in Security Grade 2.

ATC category: SP2

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication: 160500642-002 1.00, 23 November 2016
- Telefication: 20103678200rev6.0, 12 March 2014
- Telefication: 20103678800rev4.0, 13 November 2013
- Telefication: 20123698800rev1.0, 22 November 2012

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-10: 2014	June, 2014
EN 50131-3:2009	March, 2009
EN 50131-6:2008	January, 2008
EN 50136-2:2013	August, 2013

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

-



The product as described in this certificate includes the following type designations:

- Product description: Intrusion Control Panel
- Trademark: Interlogix
- Type designation: ATS4601E
- Hardware version: 1055451
- Software version: 04.11.10

- Product description: Intrusion Control Panel
- Trademark: Interlogix
- Type designation: ATS46xxE
- Hardware version: 1055451
- Software version: 04.11.10