



Certificate of Conformity

Product Certification Scheme 5

Certificate No. 21522-01-18-INT

This certificate applies to the product(s)

Warning devices

with name and/or type designation

**AS270, AS271, AS272, AS273, AS210N, AS210N-L,
AS610, AS619, AS630**

Placed on the market by

UTC Fire & Security B.V.

Kelvinstraat 7, 6003 DH Weert, Postbus 10350, 6000 GJ Weert, The Netherlands

Produced in the manufacturing plant by

Thunderous Sounders Electronic Co. Ltd.

No.21, Kai Fa 3rd Road, Pao An Industrial Area, Ren De District, Taiwan

This certificate attests that all provisions concerning the assessment and the performance described in the standard(s)

EN 50131-4:2009

are applied and that the product(s) fulfil(s) all the prescribed requirements

This Certificate is valid until 2023-01-08

Høvik, Norway 2019-01-08

For Applica Test & Certification AS

A handwritten signature in blue ink that reads 'Vibeke Vigmostad'.

Vibeke Vigmostad, Certification Manager



PROD 022

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
-	Initial Issue	2019-01-08

Product(s) Covered by this Certificate		
Product Name	Product Description	Applied Standards
AS270	Warning devices Indoor sirens	EN 50131-1:2006+A1:2009+ A2:2017 EN 50131-4:2009 EN 50130-4:2011/A1:2014 EN 50130-5:2011
AS271		
AS272		
AS273		
AS210N	Warning devices Indoor sirens	
AS210N-L		
AS610	Warning devices Outdoor sirens	
AS619		
AS630		

Product(s) Specifications		
Product Name	Environmental Class/Security Grade	Sound Level
AS270	II/2	-
AS271	II/2	-
AS272	II/2	-
AS273	II/2	-
AS210N	II/3	-
AS210N-L	II/3	-
AS610	III/3	-
AS619	III/3	The sound level of AS619 is lower than the specifications in EN 50131-4. According to the manufacturer, this product has been designed to meet the national requirements for the sound level in Spain. Ref EN50131-4, Item 5.1.2, Note 4.
AS630	III/3	-

Document(s) Reviewed	
Document ID	Description
20325 rev 01	EN 50131-1:2006+A1:2009 EN 50131-4:2009 EN 50130-4:2011
2010-3566 rev 01	EN 50131-1:2006+A1:2009, EN 50131-4:2009 EN 50130-5:1998
FB-ZERT-PRO-42e	FPC Audit report, 15.11.2017

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the product(s) listed above
- The product(s) is(are) to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The product(s) listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the product(s)
- Significant changes in the manufacturing plan(s)
- Changes in the test methods and/or factory production control requirements included in the standard(s), used to assess the performance of the declared characteristics

END OF CERTIFICATE