

# Certificate

of

Conformity

**Certificate No.: 12229085/AA/00**

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate.. This certificate relates to an ISO/IEC guide 67 system 2 registration including yearly factory inspection.

Product description: **Supervised Premises Tranceiver for I&HAS applications**

Trademark: **See annex 3**

Family name: **--**

Type designation: **See annex 3**

Serial No: **See annex 3**

Hard-|Software release No: **Rev.2.6|2.00**

Manufacturer: **ASB-Security B.V.**

Address: **Boschdijk 720**

City: **5624 CL Eindhoven**

Country: **Netherlands**

This certificate is granted to:

Name: **ASB-Security B.V.**

Address: **Boschdijk 720**

City: **5624 CL Eindhoven**

Country: **Netherlands**

**Expiry date: 19 July 2016**

This certificate has THREE Annexes.

Zevenaar, 24 July 2013



W.J.M. Jong  
Manager Product Certification



## Remarks and observations

*The following conditions are applicable:*

These products uses three different communication channels/paths:

- \* Digital Subscriber Line (DSL) (main path)
- \* Local Area Network (LAN) (secondary main path)
- \* GPRS (backup)

Equipment Security grade: 3

Equipment Environmental class: II

Equipment class: fixed

Power Supply type: A

The SPT can be applied in alarm transmission systems of the following classes and categories:

- LAN/ GPRS/ DSL (EN 50136-1:2012 Single Path): SP1, SP2, SP3, SP4, SP5 and SP6,
- LAN or DSL with GPRS (EN 50136-1:2012 Dual Path): DP1, DP2, DP3 and DP4,

The SPT can be applied for control panels of the following security grades:

- (EN 50131-1) Grade1, Grade2, Grade3 and Grade 4.

The SPT complies with the following alarm control panel interfaces: parallel, serial and PSTN according to EN 50136-1:2012.

The SPT housing complies with EN 50131-1.

## Documentation lodged for this Certificate of Conformity

### *Test Reports:*

- Telefication B.V.: 20123741800, 12 July 2013
- Telefication B.V.: 20123741801, 12 July 2013
- Telefication B.V.: 20123741804, 12 July 2013
- Telefication B.V.: 20123741805, 12 July 2013

### *Product Documentation:*

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

## Technical Standards and Specifications

*The product shows no non-compliances with:*

- DRAFT prEN 50131-10: 2011
- DRAFT prEN 50136-2: April, 2011
- EN 50130-4: June, 2011
- EN 50130-5: June, 2011
- EN 50131-6: January, 2008

## Technical features and characteristics

*The product includes the following features and characteristics:*

- Alarm equipment using RF techniques:
- Operating frequency band: Quad-band EGSM 850/ 900/ 1800/ 1900 MHz

**The product as described in this certificate includes the following type designations:**

- Product description: Supervised Premises Tranceiver for I&HAS applications
- Trademark: certiProtectOne
- Type Designation: IPC-XL
- Hardware version: Rev.2.6
- Software version: 2.00
  
- Product description: IP/GPRS Alarm Transmission Equipment for I&HAS applications
- Trademark: DigiAlarmbox
- Type Designation: DigiAlarmbox
- Hardware version: Rev.2.6
- Software version: 2.00
  
- Product description: IP/GPRS Alarm Transmission Equipment for I&HAS applications with intergrated ADSL router
- Trademark: certiProtectOne
- Type Designation: IPC-XL (DT)
- Hardware version: Rev.2.6
- Software version: 2.00