

Certificate

of
Continued Compliance

No: 13229055/AA/02

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **DGP (Data Gathering Panel)**
Trademark: **Interlogix**
Type designation: **ATS1238**
Serial No: **N/A**
Hardware / Software version: **55-950 rev B / V2.3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003DH Weert**
Country: **Netherlands**

Expiry date: **29 March 2024**

This certificate has **THREE** Annexes.

Zevenaar, 30 March 2020



Jan Willem Verwoert
Project Manager



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

The ATS1238 is meant to be installed in a UTC Fire and Security alarm control panel enclosure ATS1000A-IP-LP and ATS1000A-LP.

The ATS1238 can also be placed outside a UTC Fire and Security alarm control panel enclosure using the ATS7072 kit.

The ATS7072 kit consists of the ATS7070 (master) and ATS7071 (slave) and the housing TX-9000-03-1. The ATS1238 will be placed inside the TX-9000-03-1.

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 20103407800 - Rev. 4.0, 25 June 2014
- Telefication B.V.: 20124226200rev1.0, 10 July 2013
- Telefication B.V.: 20124226800rev1.0, 10 July 2013
- Telefication B.V.: 20124226801rev1.0, 10 July 2013
- Telefication: 160100453-004-Ver 2.00, 22 December 2017
- Telefication B.V.: 191100963-006-Ver 1.00, 25 March 2020

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50131-3	March, 2009
EN 50131-5-3	March, 2017

Applied Standards

EN 50130-5	June, 2011
EN 50131-1+A1+A2	May, 2017
EN 50130-4+A1	October, 2014



The product as described in this certificate includes the following type designations:

- Product description: DGP (Data Gathering Panel)
- Trademark: Interlogix
- Type designation: ATS1238
- Hardware version: 55-950 rev B
- Software version: V2.3
- Serial number: N/A