

CERTIFICATE

No. 000054/02

In accordance with the **CertAlarm** Rules
and Certification System 5, as defined in ISO / IEC Guide 67,
we Telefication B.V. certify that the product

DI601

is in conformity with the following standard(s)

- | | |
|------------------|----------------|
| - EN 50130-4: | December, 1995 |
| - EN 50130-4/A1: | April, 1998 |
| - EN 50130-4/A2: | January, 2003 |
| - EN 50130-5: | December, 1998 |
| - EN 50131-2-2: | January, 2008 |

UTC Fire & Security EMEA B.V.B.A.

Kouterveldstraat 2
1831 Diegem
Belgium

is authorised to use the CERTALARM Mark on the above mentioned product.

This certificate is valid until:

13 June 2014

Signed on behalf of Telefication B.V.

07 January 2014

i.o.



W.J.M. Jong
Manager Product Certification



Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000054/02 - Annex No 1

Takes into account the following product and variants:

- Product description: External PIR
- Trademark: Interlogix
- Family name: DI601
- Type Designation: DI601
- Hardware version: 2
- Software version: 1

The optional features of the specifications that are included in the product and test report:

- Equipment Security grade: 2
- Equipment Environmental class: IV
- Equipment class: Fixed

According to EN 50131-1:2006 and A1:2009, this equipment can be applied in installed systems up to and including security grade 2

Only EN 50131-2-2 compliant when mounted at a height of 3 m or less.

Test Report Numbers:

- BRE Global Limited: 274424, 27 March 2012
- Telefication B.V.: 20094423801, 07 May 2010
- Telefication B.V.: 20113601800 rev4.0, 27 July 2012

Telefication B.V.

Edisonstraat 12A
6902 PK Zevenaar
Phone : +31 316 583 180
Fax : +31 316 583 189
E-mail: certification@telefication.com
Web: www.telefication.com

CERTIFICATE

No: 000054/02 - Annex No 2

Validity of Certificate:

The Certificate remains valid based upon satisfactory annual factory production control audits for Fire products or biennial factory production control audits for Security products and follow up re-testing as required by CertAlarm scheme rules.

Documents submitted:

- Assembly drawings
- Bill of materials
- Electric diagrams
- Photos
- User manual

DISCLAIMER

The validity of this certificate is limited to products, which are equal to the one(s) examined.