



Certificate of Conformity with European standards for Components and Systems

Number of Certificate

EN-ST-000089

Valid from
dd-mm-yyyy

26-05-2019

Valid until
dd-mm-yyyy

25-05-2023

Subject matter of Certificate:

**Magnetic contact grade 2
MC 250 up**

Owner of Certificate:

**Alarmtech Sweden AB
Staffans Vag 6A
192 78 SOLLENTUNA
SCHWEDEN**

Basis for certification:

EN 50131-2-6:2008

Use, the product disposes of the following parameters:

Intrusion and hold-up systems, Grade 2

The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in **test report:**

STE08/0107-EN-MC250

VdS Schadenverhütung GmbH
Certification Body
Amsterdamer Str. 174
D-50735 Köln

A company of the German
Insurance Association (GDV)
accredited by DAKKS as certifica-
tion body for fire protection and
security products



To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises **4** pages and shall only be reproduced without any modifications and including all enclosures.

Date: 19-12-2018

Managing director

Head of certification body

To Certificate No.: EN-ST-000089

Date : 19-12-2018

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Magnetic contact up (for recessed-mounting) consisting of:</p> <ul style="list-style-type: none"> - Magnetic switch in Aluminium housing with thread $\varnothing 11 \times 22\text{mm}$ - bar magnet Nd-Fe-B with $\varnothing 7 \times 8\text{mm}$ in aluminium housing with thread $\varnothing 11 \times 14\text{mm}$ 	MC 250 up		

To Certificate No.: EN-ST-000089

Date : 19-12-2018

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Technical Documents:			
- Systemübersicht/Errichterhandbuch		26.05.1995	6
- Bill of material	MC 200-6	05.09.1995	1
- Construction drawing MC250	MC 200-3	05.09.1995	1
- Montageanleitung		28.09.2008	1
- Reed Switch Specification	Coto FR2S series	24.02.2006	1
- Datablad NM Gjutharts	NM Gjutharts 347	11.03.1993	1



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000089

Date : 19-12-2018

Instructions for the application of the approval component/system (see enclosure 1):

1. The device should not be used in material with ferromagnetic properties.
2. The device complies with the requirements of SSF1014 and with Security Grade 2 of EN 50131-2-6 and Environmental Class IIIA according to EN 50130-5.

