




Member of



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate

EN-ST-000102

Valid from  
dd-mm-yyyy

09-05-2020

Valid until  
dd-mm-yyyy

08-05-2024

Subject matter of Certificate:

**Magnetic contact grade 2  
MC 740**

Owner of Certificate:

**Alarmtech Sweden AB  
Staffans Vag 6A  
SE-192 78 SOLLENTUNA**

Basis for certification:

**EN 50131-2-6:2008-09**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 2**

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in **test report:**

**STE08/0106-MC440/440-T/540/740 dated 18-02-2009,  
STE08/0105, 0106 dated 05-06-2009**

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises **4** pages and shall only be reproduced without any modifications and including all enclosures.

**VdS Schadenverhütung GmbH**  
Certification Body  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German  
Insurance Association (GDV)  
accredited by DAkkS as certifica-  
tion body for fire protection and  
security products



Date: 27-09-2019

Managing director

Head of certification body

To Certificate No.: EN-ST-000102

Date : 27-09-2019

The approved component/system comprises the following parts:

| Description of component  | Type   | Applicant's Registration No. | Approval number of component (only complete for system approval) |
|---|--------|------------------------------|--|
| <p>Magnetic contact for surface mounting with 57,5 x 13,5 x 5 mm consisting of:</p> <ul style="list-style-type: none"> <li>- Magnetic switch in sealed plastic housing</li> <li>- magnet material ALNICO in sealed plastic housing</li> </ul> | MC 740 |                              |  |



To Certificate No.: EN-ST-000102

Date : 27-09-2019

The approved component/system is described as follows:

| Type of document           | Manufacturer's identification | Date       | Number of Pages |
|----------------------------|-------------------------------|------------|-----------------|
| Technical Documents:       |                               |            |                 |
| - Bill of material         | MC 740-10                     | 01.05.2012 | 1               |
| - Installation Instruction | MC740-11GB                    | 05.05.2012 | 1               |
| Drawings:                  |                               |            |                 |
| - Magnet and Contact Base  | CYB 2-1                       | 18.08.1998 | 1               |

**Enclosure 3**

**Sheet 1**

To Certificate No.: EN-ST-000102

Date : 27-09-2019

Instructions for the application of the approval component/system (see enclosure 1):

1. The device complies with the requirements of SSF1014-5 and Environmental Class II of EN 50131-2-6.
2. Spacers have to be used for switch and magnet part if installed on material with ferromagnetic characteristics.