



Certificate of Conformity with European standards for Components and Systems

Number of Certificate

Valid from
dd-mm-yyyy

Valid until
dd-mm-yyyy

EN-ST-000102

09-05-2012

08-05-2016

Subject matter of Certificate:

**Magnetic contact
MC 740**

Owner of Certificate:

**Alarmtech Sweden AB
Alvägen 33
SE-19133 SOLLENTUNA, SCHWEDEN**

Basis for certification:

EN 50131-2-6:2009-05

Use, the product disposes of the following parameters:

Intrusion and hold-up systems, Grade 2

VdS Schadenverhütung GmbH
Zertifizierungsstelle
Amsterdamer Str. 174
D-50735 Köln

a company of the Gesamtverband
der Deutschen Versicher-
ungswirtschaft e.V. (GDV)

is accredited according to DIN EN
ISO/IEC 17025 for testing and
according to
DIN EN 45011 for certification for
fire protection and security
systems by the Deutschen
Akkreditierungsstelle Technik
(DATech)

The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in test report:

STE08/0106-MC440/440-TI540/740

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.



DAT-ZE-005/92

Date: 09-05-2012

Managing director

Head of certification body



Enclosure 1

Sheet 1

To Certificate No.: EN-ST-000102

Date : 09-05-2012

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Magnetic contact for surface mounting with 57,5 x 13,5 x 5 mm consisting of:</p> <ul style="list-style-type: none">- Magnetic switch in sealed plastic housing- magnet material ALNICO in sealed plastic housing	MC 740		



To Certificate No.: EN-ST-000102

Date : 09-05-2012

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Technical Documents:			
- Bill of material	MC 740-10	01.05.2012	1
- Installation Instruction	MC740-11GB	05.05.2012	1
Drawings:			
- Magnet and Contact Base	CYB 2-1	18.08.1998	1



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000102

Date : 09-05-2012

Instructions for the application of the approval component/system (see enclosure 1):

1. The device complies with the requirements of SSF1014 and Security Grade 2 of EN 50131-2-6 and Environmental Class II of EN 50130-5.
2. Spacers have to be used for switch and magnet part if installed on material with ferromagnetic characteristics.