



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate

Valid from  
dd-mm-yyyy

Valid until  
dd-mm-yyyy

**EN-ST-000098**

**09-05-2020**

**08-05-2024**

Subject matter of Certificate:

**Magnetic contact grade 2  
MC 440-T**

Owner of Certificate:

**Alarmtech Sweden AB  
Staffans Vag 6A  
SE-192 78 SOLLENTUNA**

Basis for certification:

**EN 50131-2-6:2008-09**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems, Grade 2**

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in **test report:**

**STE08/0106-MC440/440-T/540/740 dated 18-02-2009,  
STE 08/0105, 0106 dated 05-06-2009**

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises **4** pages and shall only be reproduced without any modifications and including all enclosures.

**VdS Schadenverhütung GmbH**  
Certification Body  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German  
Insurance Association (GDV)  
accredited by DAkkS as certifica-  
tion body for fire protection and  
security products



Date: **27-09-2019**

Managing director

Head of certification body

To Certificate No.: EN-ST-000098

Date : 27-09-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>Magnetic contact for surface mounting consisting of:</p> <ul style="list-style-type: none"> <li>- Magnetic switch plastic housing with 65 x 20 x 15,5 mm with 6 screw terminal</li> <li>- Magnet material ALNICO 5 in plastic housing with 65 x 16 x 15 mm</li> <li>- Spacer, Cover, Screws</li> </ul>	MC 440-T		



To Certificate No.: EN-ST-000098

Date : 27-09-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Technical Documents:			
- Bill of material	MC 440-T-10	01.05.2012	1
- Installation Instruction	MC440-T-11GB	05.05.2012	1
- Reed Switch Specification	Coto FR2S series	24.02.2006	1
- Layout MC 440-T	MK 472C	12.02.1999	1
Drawings:			
- Plastic Magnet Base	CYB 2-1	12.02.1994	1
- Plastic Magnet Cover	CYB 2-2	12.02.1999	1
- Plastic Magnet Spacer	CYB 2-4	12.02.1999	1
- Plastic Contact Cover	CYB 4-1	06.06.1994	1
- Plastic Contact Base	CYB 4-2	30.06.1994	1
- Plastic Contact Base lid	CYB 4-4	06.10.1993	1
- Plastic Contact Spacer	CYB 4-5	15.06.1994	1



### Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000098

Date : 27-09-2019

Instructions for the application of the approval component/system (see enclosure 1):

1. The device complies with the requirements of SSF1014-5 and Environmental Class II of EN 50130-2-6.
2. Spacers have to be used for switch and magnet part if installed on material with ferromagnetic characteristics.

