

Certificate

of
Continued Compliance

No: 152350009/AA/00

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 system 5 registration including yearly factory inspection and market surveillance.

Product description: **Control panel**
Trademark: **Interlogix**
Type designation: **NXG-64**
Hardware / Software version: **206010 / B0403004A56P000107-18**
Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**
Address: **Kelvinstraat 7**
City: **6003 DH WEERT**
Country: **Netherlands**

Expiry date: 03-11-2019

This certificate has THREE Annexes.

Zevenaar, 03 Nov 2015

A blue ink signature of Ed de Vries.

Ed de Vries
Product Assessor



Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

According to EN 50131-1:2006, this equipment can be applied in installed systems up to and including security grade 2.

Spare part housing NXG-001 and NXG-003 are also allowed to be used with this product.

Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- ANPI asbl: BIS/REC/1332, 03 July 2015
- ANPI asbl: BIS/REC/1332 Corrigendum 1, 28 July 2015

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50130-4	June, 2011
EN 50130-5	June, 2011
EN 50131-3	March, 2009
EN 50131-6	January, 2008
EN 50131-6/A1	2014

Technical features and characteristics

The product includes the following features and characteristics:

Not specified

The product as described in this certificate includes the following type designations:

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-64
- Hardware version: 206010
- Software version: B0403004A56P000107-18

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-64IP
- Hardware version: 206010
- Software version: B0403002A56P000107-18

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-64-CPU
- Hardware version: 206010
- Software version: B0403004A56P000107-18

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-64IP-CPU
- Hardware version: 206010
- Software version: B0403002A56P000107-18

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-256IP
- Hardware version: 206010
- Software version: B0403005A56P000107-18

- Product description: Control panel
- Trademark: Interlogix
- Type designation: NXG-256IP-CPU
- Hardware version: 206010
- Software version: B0403005A56P000107-18