

Certificate

of

Continued Compliance

No: 152350010/AA/00

In compliance with the procedure specified in RD_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate.

This certificate relates to an ISO/IEC 17067 system 5 registration including yearly factory inspection and market surveillance.

Product description: Keypad

Trademark: Interlogix

Type designation: NXG-1820-EUR

Hardware / Software version: 206136 / TNFR0036

Variants: See Annex 3

Manufacturer: UTC Fire & Security B.V.

Address: Kelvinstraat 7
City: 6003 DH WEERT
Country: Netherlands

This certificate is granted to:

Name: UTC Fire & Security B.V.

Address: Kelvinstraat 7
City: 6003 DH WEERT
Country: Netherlands

Expiry date: 11-11-2019

This certificate has THREE Annexes.

Zevenaar, 11 Nov 2015

Ed de Vries Product Assessor PRODUCTS Products RVA C 224



Remarks and observations

The following conditions are applicable:

Security grade: 2 Environmental class: II Equipment class: Fixed

According to EN 50131-1:2006+A1:2009, this equipment can be applied in installed systems up to and including security grade 2



Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- ANPI asbl: BIS/REC/1332, 03 July 2015
- ANPI asbl: BIS/REC/1332 Corrigendum 1, 28 July 2015

Product Documentation:

- Assembly drawings
- Bill of materials
- Electrical diagrams
- Internal photos
- External photos
- Manual

Technical Standards and Specifications

The product shows no non-compliances with:

EN 50130-4 June, 2011 EN 50130-5 June, 2011 EN 50131-3 March, 2009

Technical features and characteristics

The product includes the following features and characteristics:

Not specified



The product as described in this certificate includes the following type designations:

- Product description: Keypad- Trademark: Interlogix

- Type designation: NXG-1820-EUR

- Hardware version: 206136- Software version: TNFR0036

- Product description: Keypad- Trademark: Interlogix

- Type designation: NX-1820E-EUR

- Hardware version: 206136- Software version: TNFX0108