

# Certificate

of  
Continued Compliance

No: 152350006/AA/00

In compliance with the procedure specified in RD\_070, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 system 5 registration including yearly factory inspection and market surveillance.

Product description: **360° Ceiling Mount Indoor PIR detector**

Trademark: **Optex**

Type designation: **SX-360Z**

Hardware / Software version: **Ver.3 / N/A**

Variants: --

Manufacturer: **Optex Co., Ltd.**

Address: **Ogoto Shiga 5-8-12**

City: **520-0101 OTSU**

Country: **Japan**

This certificate is granted to:

Name: **Optex Co., Ltd.**

Address: **Ogoto Shiga 5-8-12**

City: **520-0101 OTSU**

Country: **Japan**

Expiry date: **25-11-2019**

This certificate has THREE Annexes.

Zevenaar, 02 Dec 2015



Willem Jan Jong  
Manager Product Certification





## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

According to EN 50131-1:2006+A1:2009, this equipment can be applied in installed systems up to and including security grade 2

## Documentation lodged for this Certificate of Continued Compliance

### Test Reports:

- Telefication B.V.: 20133822800-Ver 2.00, 21 October 2015

### Product Documentation:

- Assembly drawings
- Bill of materials
- Block diagram
- Electrical diagrams
- Internal photos
- External photos
- Manual

## Technical Standards and Specifications

The product shows no non-compliances with:

EN 50130-4	June, 2011
EN 50130-5	June, 2011
EN 50131-2-2	January, 2008

## Technical features and characteristics

The product includes the following features and characteristics:

**Not specified**



**The product as described in this certificate includes the following type designations:**

- Product description: 360° Ceiling Mount Indoor PIR detector
- Trademark: Optex
- Type designation: SX-360Z
- Hardware version: Ver.3
- Software version: N/A