TEST & CERTIFICATION		
Certificate of Conformity		
Product Certification Scheme 5		
Certificate No. P20686-02-16-INT		
This certificate applies to the product Passive infrared detector		
with name and/or type designation		
NV780MX		
Placed on the market by and produced in the manufacturing plant by		
Paradox Security Systems Ltd. 780 Industriel Boulevard, St-Eustache, Québec, J7R 5V3, Canada		
This certificate attests that all provisions concerning the assessment and the performance described in the standard	١	
EN 50131-2-2:2008 are applied and that the product fulfils all the prescribed requirements		
This Certificate is valid until 2019-05-30		
Høvik, Norway 2016-05-30 For Applica Test & Certification AS		
Vibelle Vigmostad		
PROD 022		
Vibeke Vigmostad, Certification Manager		

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.



Certificate History		
Revision	Description	Issue Date
-	Initial Issue	2016-05-30

Product(s) Covered by this Certificate			
Product Name	Product Description	Applied Standards	
NV780MX		EN 50131-2-2:2008 in conjunction with	
	Passive infrared detector Wired	EN 50131-1:2006/A1:2009	
		EN 50130-4:2011/A1:2014	
		EN 50130-5:2011	

Product(s) Specifications				
Product Name	Security Grade	Environmental Class		
NV780MX	Grade 3	Class IVA		

Application/Limitation

- Suitable for indoor application

Document(s) Reviewed		
Document ID	Description	
PARIAS_EN 50131-2-2.28019 100803903MIN-003	Test report according to EN 50136-2-2:2008	
PARENV_27422_Rev.1	Test report according to EN 50130-5:2011	
PAREMC_27422	Test report according to	
PAREMC_27422_28363	EN 50130-4:2011/ A1:2014	
Audit Report CMPY-032502	Audit Report, 2015	

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.



Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the product(s) listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The product(s) listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the product(s)
- Significant changes in the manufacturing plan(s)
- Changes in the test methods and/or factory production control requirements included in the standard(s), used to assess the performance of the declared characteristics

END OF CERTIFICATE