



Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
EN-ST-000209	10-12-2019	17-03-2023

Subject matter of Certificate:

**Alarm transmission equipment
IRIS-4 620, IRIS-4 640, IRIS-4 620D, IRIS-4 640D, IRIS-4 640ARX**

Owner of Certificate:

**AddSecure AG
Bahnhofstrasse 30
CH-6300 ZUG**

Basis for certification:

**EN 50136-2:2013
EN 50131-10:2014
EN 54-21:2006**

Use, the product disposes of the following parameters:

Intrusion and hold-up systems

The tests were carried out at VdS Schadenverhütung GmbH
and the results are documented in **test report:**

140885, 140882, 140889 dated 06-03-2015

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 6 pages and shall only be reproduced without any modifications and including all enclosures.

VdS Schadenverhütung GmbH
Certification Body
Amsterdamer Str. 174
D-50735 Köln

A company of the German
Insurance Association (GDV)
accredited by DAkkS as certifica-
tion body for fire protection and
security products



Date: 10-12-2019

Managing director

Head of certification body

To Certificate No.: EN-ST-000209

Date : 10-12-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>IRIS-4 620, IRIS-4 620D, IRIS-4 640, IRIS-4 640D SPT for mounting inside existing Intruder/Fire control and indicating panels in the variants described below equipped with the common features:</p> <p>IRIS-4 640ARX (technical a IRIS-4 640D) with special ASSA branding with the common features:</p> <ul style="list-style-type: none"> - Software version V4.7.0 - USB connector for local PC configuration in combination with IRIS Toolbox software - 6 resistance supervised inputs - 4 relay outputs (electronically) - Serial interfaces (2x RS-232, 1x RS-485) with support for special control and indicating panels <p>Single path (SP6) variant with support for the following transmission path:</p> <ul style="list-style-type: none"> - 1x Ethernet (wired) - 2x Ethernet (wired) <p>Dual path (DP4) variant with support for the following transmission paths:</p> <ul style="list-style-type: none"> - GSM/GPRS (2G) - UMTS (3G) - LTE (4G) <p>and</p>	<p>IRIS-4 620D IRIS-4 620</p> <p>IRIS-4 620 only IRIS-4 620D only</p> <p>IRIS-4 640ARX IRIS-4 640D IRIS-4 640</p>		



Enclosure 1

Sheet 2

To Certificate No.: EN-ST-000209

Date : 10-12-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<ul style="list-style-type: none">- 1x Ethernet (wired)- 2x Ethernet (wired)	IRIS-4 640 only IRIS-4 640D only IRIS-4 640ARX only		

To Certificate No.: EN-ST-000209

Date : 10-12-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - IRIS-4 6 Series	Quick Installation and Maintenance Guide	14.08.2018	20
Technical Documents: - IRIS-4 620			
- Circuit diagram	IRIS-4 620, 2014-25	12.05.2018	10
- Bill of material	IRIS-4 620, Rev. D	13.05.2018	6
- Bill of material	IRIS-4 620 Packaging	15.08.2018	1
- Drawing (Label)	Label-NG-032B	15.08.2018	1
- IRIS-4 640			
- Circuit diagram	IRIS-4 640, 2014-25	12.05.2018	10
- Bill of material	IRIS-4 640, Rev. D	13.05.2018	6
- Bill of material	IRIS-4 640 Packaging	15.08.2018	1
- Drawing (Label)	Label-NG-032C	15.08.2018	1
- IRIS-4 620D			
- Circuit diagram	IRIS-4 620D, 2014-25	18.10.2019	10
- Bill of material	IRIS-4 620D, Rev. D1	28.10.2019	6
- Bill of material	IRIS-4 620D Packaging	01.11.2019	1
- Drawing (Label)	Label-NG-043A	01.11.2019	1
- IRIS-4 640D			
- Circuit diagram	IRIS-4 640D, 2014-25	18.10.2019	10
- Bill of material	IRIS-4 640D, Rev. D1	28.10.2019	6
- Bill of material	IRIS-4 640D Packaging	01.11.2019	1
- Drawing (Label)	Label-NG-043B	01.11.2019	1
- IRIS-4 640ARX			
- Circuit diagram	IRIS-4 640D, 2014-25	18.10.2019	10
- Bill of material	IRIS-4 640D, Rev. D1	28.10.2019	6

To Certificate No.: EN-ST-000209

Date : 10-12-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
- Bill of material	IRIS-4 640-ARX Packaging	28.11.2019	1
- Drawing (Label)	Label-NG-044	28.11.2019	1
- IRIS-4 all variants			
- Assembly diagram / PCB Layout	Addsecure PCB: 6xx-D DRW:2018-06	04.12.2018	8
- PCB	Manufacturing Drawing	12.05.2018	1
- Drawing (Label)	Label-NG-034	15.08.2018	1
- Drawing (Label)	Label-NG-001	15.01.2015	1
- Drawing (Label)	Carton-NG-010	15.08.2018	1
Datasheets:			
- Telit LE910EU2 (2G/3G/4G)	LE910 V Hardware User Guide, 1VV0301200, Rev. 9	15.05.2017	84



Enclosure 3

Sheet 1

To Certificate No.: EN-ST-000209

Date : 10-12-2019

Instructions for the application of the approval component/system (see enclosure 1):

The existing control and indicating panel, where the IRIS-4 620, IRIS-4 620D, IRIS-4 640, IRIS-4 640D or IRIS-4 640ARX device is mounted, specifies the EN grade of the complete alarm system.