

Certificate of Product Approval

Certificate Number: 787a

Issue: 01

Honeywell Security UK Ltd

Newhouse Industrial Estate
Motherwell
ML1 5SB



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

Honeywell MAXPRO Control and Indicating Equipment + Ancillary Equipment
(refer to appendix for details)

Standards

EN 50131-3: 2009

Alarm systems – Intrusion and hold-up systems – Part 3: Control and Indicating Equipment

EN 50131-6: 2017

Alarm systems – Intrusion and hold-up systems – Part 6: Power supplies

EN 50131-10: 2014

Alarm systems – Intrusion and hold-up systems – Part 10: Application specific requirements for Supervised Premises Transceiver (SPT)

EN 50136-2: 2013

Alarm systems – Alarm transmission systems and equipment – Part 2: Requirements for Supervised Premises Tranceiver (SPT)

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for BRE Global Ltd.

Chris Hunt
Verifier

12 March 2020
Date of Issue

12 March 2020
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 787a Honeywell Security UK Ltd

Issue: 01

Alarm Systems – Intrusion and Hold-Up Systems

Product	Product Specification	Applied Standards	LPCB Ref. No.
Honeywell MAXPRO Control and Indicating Equipment Comprising the modules listed below:- (selected according to application) MPIP3000E – Alarm panel MPIP2100E – Alarm Panel MPIP2000E – Alarm panel MPIEIO84E – 8 input/4 output expander MPIEOP4 – 4 output relay expander MPIDC1 – Door controller MPIBXM35 – Enclosure & power supply module MAXPRO Cloud application	Security Grade 3 Equipment type - Fixed Environmental Class II	EN 50131-3: 2009 Including the related requirements of: EN 50131-1:2006 + A2: 2017 EN 50130-4: 2011 + A1: 2014 EN 50130-5: 2011	787a/01
Ancillary Control Equipment MPIKTSMF – Touchscreen keypad/card reader (prox and MIFARE) MPIKTSRXX – Touchscreen keypad/card reader (prox)	Security Grade 3 Equipment type - Fixed Environmental Class II	EN 50131-3: 2009 Including the related requirements of: EN 50131-1:2006 + A2: 2017 EN 50130-4: 2011 + A1: 2014 EN 50130-5: 2011	
Power Supply MPIP3000E - Alarm panel, integrated power supply MPIP2100E - Alarm panel, integrated power supply MPIP2000E - Alarm panel, integrated power supply MPIPSU35 – Remote power supply (When fitted within MPIBXM35 enclosure)	Security Grade 3 PS Type A Equipment type - Fixed Environmental Class II	EN 50131-6: 2017 Including the related requirements of: EN 50131-1:2006 + A2: 2017 EN 50130-4: 2011 + A1: 2014 EN 50130-5: 2011	
Supervised Premises Transceiver MPIP3000E - Alarm panel with integrated single path SPT (Ethernet) MPIP2100E - Alarm panel with integrated single path SPT (Ethernet) MPIP2000E - Alarm panel with integrated single path SPT (Ethernet) MPICLTEE – 4G module (provides radio based secondary transmission path for a dual path SPT) <i>In order to provide an EN 50136 compliant ATS, the SPT must be used in conjunction with a receiving centre transceiver (RCT) which complies with the requirements of EN 50136-3.</i>	ATS Category: Ethernet/4G: DP4 Ethernet: SP5 SPT Classification: Type Z Equipment type - Fixed Environmental Class II	EN 50136-2: 2013 EN 50131-10: 2014 Including the related requirements of: EN 50136-1:2012 + A1: 2018 EN 50130-4: 2011 + A1: 2014 EN 50130-5: 2011	

This certificate and appendix is maintained and held in force through regular surveillance activities



Signed for BRE Global Ltd.

Chris Hunt

Verifier

12 March 2020

Date of Issue

12 March 2020

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

