



# INCERT CERTIFICATE

## C-001-1649/a



Issued 22-11-2023  
Expiry date 13-02-2026

Replaces C-001-1649  
Page 1 / 4

In compliance with the procedure specified in the **INCERT Scheme (Doc. Nr 005)**, Kiwa FSS products declares that the stated alarm equipment complies with the Technical standards and specifications as listed in this certificate.

Product description: Axon control panel 32 zones - 4 areas - medium metal  
Trademark: ARITECH  
Type designation: ATS1700-MM  
Hardware / Software: R55-1070-03-B / MR2.0  
Variants: See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Carrier Fire & Security B.V.  
Address: Kelvinstraat 7  
City: 6003DH Weert  
Country: Netherlands

This certificate is granted to:

Name of the certificate holder: Carrier Fire & Security EMEA bvba  
Address: De Kleetlaan 3  
City: 1831 Diegem  
Country: Belgium

Ron Scheepers  
Managing director

*This INCERT Certificate has THREE Annexes and is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standards. It does not imply an assessment on the whole production. Conformity of the produced products with the specimen tested remains on the fully responsibility of the manufacturer.*

# CERTIFICATE

Kiwa Nederland B.V.  
Kiwa FSS Products  
Wilmsdorf 50  
Postbus 137  
7300 AC Apeldoorn  
The Netherlands

<https://www.kiwa.com/nl/en/specials/fire-safety-and-security>



**Remarks and observations**

The following conditions are applicable:

Category: Control Panel

Security grade: 3

Environmental class: II

Equipment class: Fixed

Power supply type: A

SPT structure: Type Z

ATS category:

- SP4: IP with Ultrasync
- SP5: IP with OH receiver, GPRS with OH or Ultrasync receiver
- DP3: IP and GPRS with Ultrasync receiver
- DP4: IP and GPRS with OH receiver

Factory location:

Carrier Manufacturing Polska Sp. z o.o.

24 Kolejowa street

Ropczyce

Poland

Product inspection location:

Carrier Fire & Security B.V.

Kelvinstraat 7

Weert

Netherlands

**Documentation lodged for this INCERT certificate**

## Test Reports:

- Kiwa Nederland B.V.: P000240476-ENV-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-001-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-002-Ver 1.00, 26 June 2023
- Kiwa Nederland B.V.: P000240476-003-Ver 1.00, 23 June 2023
- Kiwa Nederland B.V.: P000240476-004-Ver 1.00, 01 September 2023

## Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Mechanical drawings
- Label and label placement

**Technical Standards and Specifications**

The product shows no non-compliances with:

T 031+A1+A2

August, 2022

**Applied Standards**

EN 50131-3	March, 2009
EN 50130-5	June, 2011
EN 50136-2	August, 2013
EN 50131-10	June, 2014
EN 50130-4+A1	October, 2014
EN 50131-6+A1	June, 2021
EN 50136-1+A1	November, 2018
EN 50131-1+A1+A2+A3	June, 2020

**The product as described in this certificate includes the following type designations**

- Product description: Axon control panel 32 zones - 4 areas - medium metal  
- Trademark: ARITECH  
- Type designation: ATS1700-MM  
- Hardware version: R55-1070-03-B  
- Software version: MR2.0

- Product description: Axon control panel 256 zones - 16 areas - medium metal  
- Trademark: ARITECH  
- Type designation: ATS3700-MM  
- Hardware version: R55-1070-03-B  
- Software version: MR2.0