



Certificate of Conformity

Product Certification Scheme 5

Certificate No. 31674-01-25-INT

This certificate applies to the products

Wireless LuNAR FireWatch Smoke, Heat & PIR

with name and/or type designation

RWX35SPA

Placed on the market by

Risco Ltd.

Head office: 14 Hachoma Street, 75655 Rishon LeZion, Israel

Manufacturing plant: Risco Ltd., 6 Sderot Yahalom Street, Kiryat-Gat, Israel

This certificate attests that all provisions concerning the assessment and the performance described in the standard

EN 50131-2-2:2021

EN 50131-6:2017/A1:2021

are applied and that the products fulfils all the prescribed requirements

This Certificate is valid until 2029-02-04

Høvik, Norway 2025-02-04

For Applica Test & Certification AS

A handwritten signature in blue ink, appearing to read 'Jan Rune Pedersen'.

Jan Rune Pedersen, Certification Manager



Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no

Certificate History		
Revision	Description	Issue Date
-	Initial Issue	2025-01-02-04

Products Covered by this Certificate		
Product Name	Product Description	Applied Standards
RWX35SPA	Wireless LuNAR FireWatch Smoke, Heat & PIR, 868Mhz	EN 50131-2-2:2021 in conjunction with EN 50131-1:2006/A1:2009 /A2:2017/A3:2020 EN 50130-4:2011/A1:2014 EN 50130-5:2011 EN 50131-5-3:2017 EN 50131-6:2017/A1:2021

Product Specifications	
Product Name	Power Supply Type
RWX35SPA	EN 50131-6:2017/A1:2021 Type C

Application/Limitation

- Security Grade 2
- Environmental Class II
- Suitable for indoor application

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Documents Reviewed	
Document ID	Description
RISEMC_EN.54843	EN 50130-4:2011/A1:2014
RISRAD_EN.36328_EN 50131-5-3	EN 50131-5-3:2017
RISENV_EN.54843	EN 50130-5:2011
RISIAS_EN 50131-2-2.54843	EN 50131-2-2:2021 EN 50131-1:2006/A1:2009/A2:2017/A3:2020
RISIAS_EN 50131-6.54843	EN 50131-6:2017/A1:2021
LAB/BIS/REC/1546	EN 50130-5:2011, (SO ₂ test)
Risco_OD CIG 023 - November 2020_Jul2024	FPC rapport

Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The products are to be used in accordance with the manufacturer installation and operation instructions
- The Certificate remains valid based upon satisfactory bi-annual factory production control audits
- The products listed in this certificate have been found to comply with the requirements of ISO/IEC 17065:2012 and ISO/IEC 17067:2013 for Product Certification Scheme 5

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Significant changes in the manufacturing plant
- Changes in the test methods and/or factory production control requirements included in the standards, used to assess the performance of the declared characteristics

END OF CERTIFICATE

Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of certified product and/or significant changes in production process may render this certificate invalid.

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. www.applica.no