

# Certificate of Continued Compliance 13229032/AA/05



Issued Expiry date 12-08-2022 08-11-2024

Replaces Page 13229032/AA/04 1 / 4

In compliance with the procedure specified in the **Alarm Components Scheme**, Kiwa FSS products declares that the stated alarm equipment complies with the technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: Trademark: Type designation: Serial No: Hardware / Software: Variants:

PIR Detector Anti Mask Aritech VE735AM N/A 0736R3 / V2.01 See Annex 3

Placed on the market under the name or trademark of:

Name of the manufacturer: Address: City: Country: Carrier Fire & Security B.V. Kelvinstraat 7 6003DH Weert Netherlands

This certificate is granted to:

Name of the certificate holder: Address: City: Country: Carrier Fire & Security B.V. Kelvinstraat 7 6003DH Weert Netherlands

Ron Scheepers Managing director

This certificate has THREE Annexes.



https://www.kiwa.com/nl/en /specials/fire-safety-and-security

Telefication B.V. Kiwa FSS Products

Wilmersdorf 50

Postbus 137 7300 AC Apeldoorn The Netherlands

#### Remarks and observations

The following conditions are applicable:

Security grade: Grade 3 Environmental class: II Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 3.

### Documentation lodged for this Certificate of Continued Compliance

Test Reports:

- Telefication B.V.: 20113812805 rev 1.0, 18 December 2012
- Telefication B.V.: 20143542801-Ver 1.00, 30 July 2014
- Telefication B.V.: 99636280 Rev. 3, 26 January 2010
- Telefication: 180701556-001-Ver. 1.00, 26 March 2019
- Telefication B.V.: 200301447-001-Ver. 1.00, 08 July 2020
- Telefication B.V.: P000118234-001-Ver. 1.00, 29 July 2022

Product Documentation:

- Assembly drawings
- Bill of material / Parts list
- Electronic schematics
- Manual
- Internal / external photos
- Label and label placement

#### **Technical Standards and Specifications**

The product shows no non-compliances with:

EN 50131-2-2

November, 2017

#### **Applied Standards**

EN 50130-5 EN 50130-4+A1 EN 50131-1+A1+A2+A3 June, 2011 October, 2014 June, 2020

## The product as described in this certificate includes the following type designations

<ul> <li>Product description:</li> <li>Trademark:</li> <li>Type designation:</li> <li>Hardware version:</li> <li>Software version:</li> <li>Serial number:</li> </ul>	PIR Detector Anti Mask Aritech VE735AM 0736R3 V2.01 N/A
<ul> <li>Product description:</li> <li>Trademark:</li> <li>Type designation:</li> <li>Hardware version:</li> <li>Software version:</li> <li>Serial number:</li> </ul>	PIR Detector Anti Mask Aritech VE736AM 0736R3 V2.01 N/A